



**NOTES:**

- \* CONCRETE STRENGTH IS 4,000 PSI @ 28 DAYS
- \* STRUCTURE JOINTS TO BE SEALED WITH FLAT BUTYL SEALANT (RAM-NEK)
- \* STANDARD PUMP CONFIGURATION SHOWN
- \* 56 GPM AT 15'TDH



28021 Coker-Vail Road Holden, LA  
 Phone (225) 567 - 2700 Fax (225) 567 - 3089  
 www.gaineyconcrete.com

<b>60" INFLUENT LIFT STATION</b>	
MODEL #	GCP LS -60
	12/9/08