



- NOTES:**
- * CONCRETE STRENGTH IS 4,000 PSI @ 28 DAYS
 - * STRUCTURE JOINTS TO BE SEALED WITH FLAT BUTYL SEALANT (RAM-NEK)
 - * STANDARD PUMP CONFIGURATION SHOWN
 - * 56 GPM AT 15'TDH



28021 Coker-Vail Road Holden, LA
 Phone (225) 567 - 2700 Fax (225) 567 - 3089
 www.gainneysconcrete.com

72" INFLUENT LIFT STATION

NTS	4/18/07
-----	---------